



STONE-LINED COMMERCIAL AQUA BOOSTER

Suggested Specification Form

Storage tanks shall be Commercial Aqua Booster Model _____ CD, nominal capacity of _____ U.S. gallons. Inner tank shall be steel, lined with HYDRASTONE® and mounted on three heavy duty legs, have a working pressure of 150 p.s.i. and rated test pressure of 300 p.s.i.

All tank fittings shall be of silicon bronze. All water connections shall be 1½" i.p.s. brass fittings.

Storage tank shall be equipped with an immersion adjustable thermostat (100° F. to 160° F.) for mounting in the immersion well.

The tank shall be insulated with a minimum of 2" of urethane foam.

The tank shall be enclosed in a plastic jacket, top and base.

The shipping container shall be of a see-through shrink wrap to enable inspection of the heater, and will include a drip pan for optional use.

Storage tank shall be backed with a limited 5 year warranty.